



# ENVIROCHECK

Recognised by MoEF&CC, WBPCB & JSPCB  
Accredited by NABL (ISO/IEC 17025:2017)  
Certified by ISO 9001:2015, ISO 14001:2015 & ISO 45001:2018



**FORMAT NO. ENV/FM/40**

## TEST REPORT

Name of the Industry	: Greenzen Bio Pvt. Ltd.	Type of Industry	: Bio-Medical Waste Treatment Plant		
Address	: Mouza - Binnaguri, J. L. No. - 3, Site No. - 12, Fulbarihat, Bhaktinagar, Jalpaiguri, Pin - 734015	Sampling Date	: 03.05.2022		
		Period of Analysis	: 05.05.2022 - 09.05.2022		
		Date of Issue	: 10.05.2022		
Sampling Plan & Procedure	: ENV/SOP/01	Deviation from the Sampling Method and Plan	: No	Type of Sample	: Effluent Water (Grab)
Location	: E.T.P Inlet	Sample ID No.	: ENV/211/W/M/I	Report No.	: ENV/211/TR(W)/M/I/22-23

SL. NO.	PARAMETERS	TEST METHOD	UNIT	RESULTS
1.	pH value	4500 H+B APHA 23 <sup>rd</sup> Edition, 2017	-	6.38
2.	Total Suspended solids	2540 D APHA 23 <sup>rd</sup> Edition, 2017	mg/l	120.0
3.	Oil & Grease	5520 Oil B/D APHA 23 <sup>rd</sup> Edition, 2017	mg/l	16.50
4.	Chemical Oxygen Demand	5200 COD B/C/D APHA 23 <sup>rd</sup> Edition, 2017	mg/l	920.0
5.	Biochemical Oxygen Demand for 3 days at 27°C	5210 BOD B APHA 23 <sup>rd</sup> Edition, 2017	mg/l	230.0

Reviewed By :

**DURBADAL CHAKRABORTY**  
Dy. Quality Manager

Approved By :

**Dr. AJOY PAUL**  
Quality Manager



# ENVIROCHECK

Recognised by MoEF&CC, WBPCB & JSPCB  
Accredited by NABL (ISO/IEC 17025:2017)  
Certified by ISO 9001:2015, ISO 14001:2015 & ISO 45001:2018



**FORMAT NO. ENV/FM/40**

## TEST REPORT

Name of the Industry	: Greenzen Bio Pvt. Ltd.	Type of Industry	: Bio-Medical Waste Treatment Plant		
Address	: Mouza - Binnaguri, J. L. No. - 3, Site No. - 12, Fulbarihat, Bhaktinagar, Jalpaiguri, Pin - 734015	Sampling Date	: 03.05.2022		
		Period of Analysis	: 05.05.2022 - 09.05.2022		
		Date of Issue	: 10.05.2022		
Sampling Plan & Procedure	: ENV/SOP/01	Deviation from the Sampling Method and Plan	: No	Type of Sample	: Effluent Water (Grab)
Location	: E.T.P Outlet	Sample ID No.	: ENV/211/W/M/II	Report No.	: ENV/211/TR(W)/M/II/22-23

SL. NO.	PARAMETERS	TEST METHOD	UNIT	RESULTS
1.	pH value	4500 H+B APHA 23 <sup>rd</sup> Edition, 2017	-	6.72
2.	Total Suspended solids	2540 D APHA 23 <sup>rd</sup> Edition, 2017	mg/l	26.0
3.	Oil & Grease	5520 Oil B/D APHA 23 <sup>rd</sup> Edition, 2017	mg/l	<1.0
4.	Chemical Oxygen Demand	5200 COD B/C/D APHA 23 <sup>rd</sup> Edition, 2017	mg/l	80.0
5.	Biochemical Oxygen Demand for 3 days at 27°C	5210 BOD B APHA 23 <sup>rd</sup> Edition, 2017	mg/l	26.0

Reviewed By :

**DURBADAL CHAKRABORTY**  
Dy. Quality Manager

Approved By :

**Dr. AJAY PAUL**  
Quality Manager